

Unite Fire & Security  
Dollys Lane  
Stoke on Trent  
ST6 7AW



## Appointment Report & Test Results

Install Ref	619	AC Ref	Cheddlet
System	Fire Alarm System	Chip No	
Customer Address		Installation Address	
Cheddleton Community Centre Hollow Lane Cheddleton Leek ST13 7LF		The Old School Craft Centre Tea Room Hollow Lane Cheddleton ST13 7HP	

Type	JOB	
No	7344	
Created By:	summerb	
Created Date/Time:	19/01/26 / 9:10	
App No/ Cert	7300 / 2626	
Engineer	Russell Lloyd	
Onsite Start/End	19/01/26 9:30 AM	19/01/26 10:30 AM
Total Time (h:m)	On Site 01:00	Travel
Customer Position		
Signature		

### JOB DETAILS & HISTORY

#### Job Details A scheduled SERVICE for Installation Ref No 619

##### Work Undertaken

19/01/26 App ID : 7300

[09:30 - 10:30] Russell Lloyd

Checked accessible devices.  
Unable to access zone 3 beauty rooms as no key available.  
Panel in fire on arrival activated by sound alarm button.  
Zone 3 in fault on arrival, unable to check due to no access.  
Buzzer on panel is faulty, does not work.  
Checked battery backups.  
Checked accessible sounders.  
CTech conventional panel 4zone  
Revisit 2 x men required with access to all areas to trace fault on zone 3

##### Unite Fire & Security Regulatory Scheme Membership

BAFE Registration: 102982

NICEIC Registration:

NSI Intruder Registration:

NSI Fire Registration:

SSAIB Registration: STAF069

##### Compliance Statement

###### Service Information

Service/ Service Cycle 3 / 6

Last/Next Service 03/07/25

/ 23/07/26

I/We certify that the Fire Alarm System system in the above premises has been inspected and tested in accordance with current standards and all appropriate legislation.

Signature Russell Lloyd

19/01/2026

On behalf of: Unite Fire & Security

